



8165 E Kaiser Blvd. Anaheim, CA 92808
www.lightlaboratory.com

Report No: L081910608



Report No: L081910608

Issue Date: 8/21/2019

Report Prepared For: Number Eight Lighting Company
526 Portal Street, Cotati, CA 94931

Model Number: 201-R-HI-3000-60/DIM1-2-SO/FLR-2-WH

Test: Photometric/Electrical Test

Standards Used: Appropriate part or all test guidelines were used for test performed:

IESNA LM79: 2008 Approved Methods for Electrical and Photometric Measurements of Solid-State Lighting Products

ANSI NEMA ANSLG C78.377: 2008 Specification of the Chromaticity of Solid State Lighting Products

ANSI C82.77:2002: Harmonic Emission Limits-Related Quality Requirements for Lighting Equipment

Description of Sample: Client submitted the sample. Received in working and undamaged condition. No modifications were necessary.

Special Test Condition: Fixture is tested with no special conditions.

Sample Arrival Date: 8/16/19

Date of Tests: 8/19/19 - 8/21/19

Seasoning of Sample: No seasoning was performed in accordance with IESNA LM-79.

Equipment List

Equipment Used	Model No	Stock No	Calibration Due Date
Chroma Programmable AC Source	61604	PS-AC02	--
Yokogawa Digital Power Meter	WT210	MT-EL06-S4	1/9/21
BK PRECISION	1747	PS-DC04	1/10/21
Fluke Digital Thermometer	52K/J	MT-TP05	1/10/21
LLI Type C Goniophotometer System	RMG-C-MKII	CD-LL04-GC	--
LLI 2M Sphere	2MR97	CD-SN03-S2	--
LLI Spectroradiometer	SPR-3000	MT-SC01-S2	Before Use

General Information

Manufacturer:	Number Eight Lighting Company
Model Number:	201-R-HI-3000-60/DIM1-2-SO/FLR-2-WH
Driver Model Number:	INTUITIVE SYSTEMS ISD-701-350-15-D

Photometric & Electrical Test Results

Total Lumens:	1036.35
Efficacy:	72.72
Input Voltage (VAC/60Hz):	119.96
Input Current (Amp):	0.1196
Input Power (W):	14.25
Input Power Factor:	0.9932
Current ATHD (%):	5.6%

Test Condition

Ambient Temperature (°C):	25.0
Stabilization Time (Hours):	1:00
Total Operating Time (Hours):	2:05




FIG. 1 LUMINAIRE

Test Methods

Photometric Measurements - Goniophotometer

A Custom Light Laboratory Type C Rotating Mirror Goniophotometer was used to measure candelas(intensity) at each angle of distribution as defined by IESNA for the appropriate fixture type.

Ambient temperature is set to 25°C and is measured from the center of the fixture, within 1ft from the outside of the fixture. Temperature is maintained at 25°C throughout the testing process and the sample is stabilized for at least 30mins and longer as necessary for the sample to achieve stabilization.

Electrical measurements are measured using the listed equipment.

Spectral Measurements - Integrating Sphere

A Sensing Spectroradiometer SPR-3000, in conjunction with Light Laboratory 2 meter integrating sphere was used to measure chromaticity coordinates, correlated color temperature(CCT) and the color rendering index(CRI) for each sample.

Ambient temperature is set to 25°C and is measured from the center of the fixture, within 1ft from the outside of the fixture. Temperature is maintained at 25°C throughout the testing process and the sample is stabilized for at least 30mins and longer as necessary for the sample to achieve stabilization.

Electrical measurements are measured using the listed equipment.

Disclaimers:

This report must not be used by the customer to claim product certification, approval or endorsement by NVLAP, NIST or any agency of Federal Government.

Report Prepared by : Keyur Patel

Test Report Reviewed by:



Steve Kang
Quality Assurance

**Attached are photometric data reports. Total number of pages: 9*



8165 E. Kaiser Blvd. Anaheim, CA 92808
 www.lightlaboratory.com

Photometric Test Report

IES INDOOR REPORT
PHOTOMETRIC FILENAME : L081910608.IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002
 [TEST] L081910608
 [TESTLAB] LIGHT LABORATORY, INC. (www.lightlaboratory.com)
 [ISSUEDATE] 8/21/2019
 [MANUFAC] Number Eight Lighting Company
 [LUMCAT] 201-R-HI-3000-60/DIM1-2-SO/FLR-2-WH
 [LUMINAIRE] LED Recessed Fixed Position Downlight, 3000K 90+ CRI, 60° Beam Spread,
 [MORE] Standard Output 1% Dimming Driver, Round Flanged Trim, \varnothing 1.875" Aperture
 [BALLASTCAT] INTUITIVE SYSTEMS ISD-701-350-15-D
 [OTHER] INDICATING THE CANDELA VALUES ARE ABSOLUTE AND
 [MORE] SHOULD NOT BE FACTORED FOR DIFFERENT LAMP RATINGS.
 [INPUT] 119.96VAC, 14.25W
 [TEST PROCEDURE] IESNA:LM-79-08

CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	1036
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	73
Total Luminaire Watts	14.25
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	0.90
Spacing Criterion (90-270)	0.90
Spacing Criterion (Diagonal)	0.80
Basic Luminous Shape	Circular
Luminous Length (0-180)	0.15 ft (Diameter)
Luminous Width (90-270)	0.15 ft (Diameter)
Luminous Height	0.00 ft

LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	31412	31412	31412
55	5305	5305	5305
65	0	0	0
75	0	0	0
85	0	0	0

CANDELA TABULATION

	<u>0</u>
0.0	1428
1.0	1412
3.0	1415
5.0	1416
7.0	1414
9.0	1399
11.0	1366
13.0	1326
15.0	1283
17.0	1231
19.5	1149
22.5	1024
25.5	833
29.0	533
33.0	256
37.5	105
42.5	49
47.5	24
55.0	5
65.0	0
75.0	0
85.0	0
90.0	0

IES INDOOR REPORT
PHOTOMETRIC FILENAME : L081910608.IES

ZONAL LUMEN SUMMARY

Zone	Lumens	%Lamp	%Fixt
0-20	470.59	N.A.	45.40
0-30	842.91	N.A.	81.30
0-40	983.41	N.A.	94.90
0-60	1033.98	N.A.	99.80
0-80	1036.35	N.A.	100.00
0-90	1036.35	N.A.	100.00
10-90	927.15	N.A.	89.50
20-40	512.83	N.A.	49.50
20-50	554.10	N.A.	53.50
40-70	52.94	N.A.	5.10
60-80	2.37	N.A.	0.20
70-80	0.00	N.A.	0.00
80-90	0.00	N.A.	0.00
90-110	0.00	N.A.	0.00
90-120	0.00	N.A.	0.00
90-130	0.00	N.A.	0.00
90-150	0.00	N.A.	0.00
90-180	0.00	N.A.	0.00
110-180	0.00	N.A.	0.00
0-180	1036.35	N.A.	100.00

Total Luminaire Efficiency = N.A.%

ZONAL LUMEN SUMMARY

Zone	Lumens
0-10	109.20
10-20	361.38
20-30	372.32
30-40	140.50
40-50	41.28
50-60	9.29
60-70	2.37
70-80	0.00
80-90	0.00
90-100	0.00
100-110	0.00
110-120	0.00
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00


IES INDOOR REPORT
PHOTOMETRIC FILENAME : L081910608.IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0	
	RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100	0
1	114	111	109	107	111	109	107	105	105	103	102	101	100	99	98	97	96	94	0
2	109	104	100	97	106	102	99	96	99	96	94	96	94	92	93	92	90	88	0
3	104	98	93	89	102	96	92	88	94	90	87	91	88	86	89	86	84	83	0
4	99	92	86	82	97	91	86	82	88	84	81	86	83	80	85	82	79	78	0
5	94	86	81	77	93	85	80	76	84	79	76	82	78	75	80	77	74	73	0
6	90	81	76	72	88	81	75	71	79	74	71	78	74	71	76	73	70	69	0
7	86	77	71	67	84	76	71	67	75	70	67	74	70	66	73	69	66	65	0
8	82	73	67	63	81	72	67	63	71	66	63	70	66	63	69	65	62	61	0
9	78	69	64	60	77	69	63	60	68	63	59	67	62	59	66	62	59	58	0
10	75	66	60	56	74	65	60	56	64	60	56	64	59	56	63	59	56	55	0

POLAR GRAPH



Maximum Candela = 1428 Located At Horizontal Angle = 0, Vertical Angle = 0
1 - Vertical Plane Through Horizontal Angles (0 - 180) (Through Max. Cd.)
2 - Horizontal Cone Through Vertical Angle (0) (Through Max. Cd.)

ILLUMINANCE CONE DIAGRAM: BEAM (50%)
MOUNT HEIGHT(Ft): 12

